

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7170-1341:104 Page 1 of 1

CATEGORY: Control Unit (High-Rise)

LISTEE: Safetech International Inc, 9550 Dice Lane, Lenexa, KS 66215
Contact: Gaylen Davenport (913) 894-4855

DESIGN: Model 3000 analog addressable fire alarm control units. Power-limited, automatic, manual, local, coded, non-coded, remote station (protected premise unit), central station (protected premise unit), waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations.
System components:

<u>Model</u>	<u>Part No.</u>	<u>Description</u>
Power Chassis +	3000-6418	PCS & TEK200SD/300SD Power Supply
S3000 Sub-Assembly	3000-6410	CP3 and LPD
RPC	3000-6860	Remote Power Converter
ACM	3000-6055	Addressable Communication Module
CBM	3000-6025	City Box Module
ICP	3000-6830	Isolated Communication Port
SCP3	3000-6835	Serial Communication Port
TZB@	2936	Ten Zone Board
ZRM@	2918	Zone Relay Module
FZA@	2941	Fire Zone Board
RLD, -EX@	4035, 4040	Remote LED Driver
RDA	3000-6807	Remote Display Annunciator

RATING: Primary: 120/220 VAC (Auto Selectable)
Secondary: 24 VDC battery

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as fire alarm control unit suitable for high rise applications when used with separately listed compatible initiating and indicating devices and Models EVAC 2101 and 2101-RMT (CSFM Listing No. 6911-1393:103) or EVAC 101-RMT (CSFM Listing No. 6911-1393:104) Voice Evacuation/Communication systems.

01-07-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**